



GEOTECHNICAL & MATERIALS
ENGINEERING, TESTING & INSPECTION
P.O. BOX 15732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No.1450

SIEVE ANALYSIS

PROJECT: Product Check
53rd St. Yard

PROJECT NO: TL-8047

CLIENT: Transcor Recycling LLC

DATE: February 9, 2016

SAMPLE LOCATION: 53rd Street Processing Facility – Stockpile

SAMPLE DESCRIPTION: Non-FDOT underdrain SAND

<u>Sieve Number</u>	<u>Percent Passing</u>	<u>Fine Aggregate ASTM C 33</u>
3/8"	100	100
No. 4	100	95-100
No. 8	99	80-100
No. 16	99	50-85
No. 30	94	25-60
No. 50	60	5-30
No. 100	10	0-10
No. 200	0.5	0-3

FINENESS MODULUS: 1.38

DATE SAMPLED: 02/03/16

DATE TESTED: 02/09/16

IGOR (IGON) KRATSER, P.E.
Florida License No. 73129