



PROJECT:

Product Check

PROJECT NO:

TL-8047

CLIENT:

Kimmins Contracting Corporation

DATE:

July 6, 2010

SAMPLE LOCATION:

53rd Street Processing Facility - Stockpile

SAMPLE DESCRIPTION:

No. 57 Aggregate (Crushed Concrete)

Sieve Number	Percent Passing	No. 57 Aggregate ASTM C 33
11/211	100	100
1 11	100	95-100
3/4"	87	
1/2"	23	25-60
3∕8°°	9	V- M 104
No 4	4	01-0
No 8	3 2	0-5

FINENESS MODULUS: 6 96

DATE SAMPLED:

6/30/10

DATE TESTED:

7/1/10

REPORTS TO:

Kimmins Contracting Corporation Attn; Eric Wilhelm (2)

ewithelm@kimmins.com

TEST LAB, INC.