



**GEOTECHNICAL & MATERIALS
ENGINEERING, TESTING & INSPECTION**
P.O. BOX 15732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No.1450

SIEVE ANALYSIS

PROJECT: Product Check
Four Corners

PROJECT NO: TL-8047

CLIENT: Transcor Recycling LLC

DATE: 3/02/16

LAB NO.: 21190

SAMPLE LOCATION: Stockpiled at Four Corners Processing Facility

SAMPLE DESCRIPTION: Coarse Aggregate – No. 57 Limestone

<u>Sieve Number</u>	<u>Percent Passing</u>	<u>No. 57 Aggregate ASTM C 33</u>
1 1/2"	100	100
1"	86	95-100
3/4"	69	—
1/2"	30	25-60
3/8"	10	—
No. 4	5	0-10
No. 8	4	0-5

FINENESS MODULUS: 7.13

DATE SAMPLED: 2/16/16

DATE TESTED: 2/29/16

