



SOIL ANALYSIS

GEOTECHNICAL & MATERIALS  
ENGINEERING, TESTING & INSPECTION  
P.O. BOX 15732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No. 1450

PROJECT: Product Check - P.O. No. 7500-02  
16410 Balm Wimauma Rd

PROJECT NO: TL-8047

CLIENT: Transcor Recycling LLC

DATE: 8/31/2016

LAB NO: 21650

SAMPLE LOCATION: Stockpile

SAMPLE DESCRIPTION: Light brown fine SAND

<u>Sieve Number</u>	<u>Percent Passing</u>
No. 4	100.0
No. 10	100.0
No. 20	98.9
No. 40	93.6
No. 60	73.8
No. 100	37.3
No. 140	15.4
No. 200	4.6

ATTERBERG LIMITS: LL: NP PL: NP PI: NP

AASHTO SOIL CLASSIFICATION: A-3

DATE SAMPLED: 8/26/16

DATE TESTED: 8/30/16

SHANNON R. SNYDER, P.E.  
Florida License No. 57019