



SOIL ANALYSIS

GEOTECHNICAL & MATERIALS
ENGINEERING, TESTING & INSPECTION
P.O. BOX 15732 - TAMPA, FLORIDA 33684 - 813/872-7821 CA No.1480

PROJECT: Product Check - P.O. No. 7001-95000
Wimauma

PROJECT NO: TL-8047

CLIENT: Transcor Recycling LLC

DATE: 7/2/2020

LAB NO.: 24024

SAMPLE LOCATION: Stockpile

SAMPLE DESCRIPTION: Light brown fine SAND
(Backfill Material)

<u>Sieve Number</u>	<u>Percent Passing</u>	<u>FDOT Specifications</u> <u>548-2.6.2</u>
3 1/2"	100.0	100
3/4"	100.0	70-100
1/2"	100.0	---
3/8"	100.0	---
No. 4	99.9	30-100
No.10	99.7	---
No. 40	95.8	15-100
No. 60	77.1	---
No. 80	35.7	---
No. 100	21.9	0-65
No. 140	6.8	---
No. 200	5.3	0-12


ATTERBERG LIMITS: LL: NP PL: NP PI: NP

AASHTO SOIL CLASSIFICATION: A-3

pH: 6.27

DATE SAMPLED: 6/25/20

DATE TESTED: 7/1/20



Connie A. Johnson-Gearhart 7/8/20
CONNIE A. JOHNSON-GEARHART, P.E.
Florida License No. 69013